

ADICHUNCHANAGIRI INSTITUTE OF TECHNOLOGY



Estd: 1980

Accredited by NBA, NAAC,
Affiliated to VTU, Belagavi
Recognised by AICTE, New Delhi, and Govt. of Karnataka
PB No. 91, Adichunchanagiri Extension, KM Road,
CHIKKAMAGALURU 577102, KARNATAKA, INDIA
Phone: Office: 220444, Principal: 220063, Residence: 220343,
Fax: 220063, STD code: 08262



DEPARTMENT OF CIVIL ENGINEERING

Name of the School: Sri Sai Angels School, Located at Assesment No.165, Sirgapura, Mallur Post, Chikkamagaluru (D).

NDT Results

Table 1: NDT Results of Sri Sai Angels School.

Sl No	Structural Member	Recorded Compressive Strength (MPa)
1	Column 1	26
2	Column 2	27
3	Column 3	26
4	Column 4	26
5	Column 5	25
6	Column 6	26
7	Beam 1	26
8	Beam 2	25
9	Beam 3	26
10	Slab 1	27
11	Slab 2	26
12	Slab 3	27

NOTE:

1. Table 1 and 2 are the recorded Compressive Strengths of different structural elements. It is obtained from the Rebound Hammer reading collected during the day of inspection and geo tag photos are attached for the reference.
2. These values are in-situ obtained on the particular day of visit. It may vary accordingly based on type of instrument.


Faculty In-Charge
CHETHAN V R
Assistant Professor
Dept. of Civil Engineering
AIT, Chikkamagaluru
Ph. 8197737677


HOD
Dr. KIRAN B. M.
Professor & Head B.E., M.Tech., Ph.D.
Department of Civil Engineering
Adichunchanagiri Institute of Technology
CHIKKAMAGALURU-577102


Principal
Principal
Adichunchanagiri Institute of Technology
Chikkamagaluru - 577102

ADICHUNCHANAGIRI INSTITUTE OF TECHNOLOGY



Estd: 1980

Accredited by NBA, NAAC,
Affiliated to VTU, Belagavi
Recognised by AICTE, New Delhi, and Govt. of Karnataka
PB No. 91, Adichunchanagiri Extension, KM Road,
CHIKKAMAGALURU 577102, KARNATAKA, INDIA
Phone: Office: 220444, Principal: 220063, Residence: 220343,
Fax: 220063, STD code: 08262




DEPARTMENT OF CIVIL ENGINEERING

BUILDING FITNESS CERTIFICATE

1.	Building Name	Sri Sai Angels School
2.	Address	Sri Sai Angels School , Sirgapura Mallur Post Chikkamagluru-577133
3.	Classification of Building	Education Purpose
4.	Location, Street No., Ward No., /Name of the Place or Panchayath	Sirgapura Mallur Post Chikkamagluru-577133
5.	Period for which the certification is issued	27.05.2026-26.05.2030
6.	Nature of Defects, if any a. Foundations Basement b. Superstructure c. Doors & Windows d. Roof e. Flooring f. Miscellaneous (Crack,etc.)	No Visual Defects No Visual Defects No Visual Defects No Visual Defects No Visual Defects No
7.	Any Major Defects noticed which will Render the building unsafe in any manner	No
8.	Whether maintenance works have been Done properly	Yes
9.	Whether the structure is sound or not For Occupancy	Sound Fit
It is certified that the School Building was inspected on 27.05.2026 and found to be fit/until for occupancy, for the period of 27.05.2026-26.05.2030 for the reasons stated above.		


Faculty In-Charge
CHETHAN V R
Assistant Professor
Dept. of Civil Engineering
AIT, Chikkamagaluru
Ph. 8197737677


HOD


Principal
Principal
Adichunchanagiri Institute of Technology
Chikkamagaluru - 577102

ADICHUNCHANAGIRI INSTITUTE OF TECHNOLOGY



Estd: 1980


Accredited by NBA, NAAC,
Affiliated to VTU, Belagavi
Recognised by AICTE, New Delhi, and Govt. of Karnataka
PB No. 91, Adichunchanagiri Extension, KM Road,
CHIKKAMAGALURU 577102, KARNATAKA, INDIA
Phone: Office: 220444, Principal: 220063, Residence: 220343,
Fax: 220063, STD code: 08262


DEPARTMENT OF CIVIL ENGINEERING



Name of the School: Sri Sai Angels School, Located at Assesment No.165, Sirgapura, Mallur Post, Chikkamagaluru (D).

GEO TAG PHOTOS




Faculty In-Charge
CHETHAN V R
Assistant Professor
Dept. of Civil Engineering
AIT, Chikkamagaluru
Ph. 8197737677


Dr. KIRAN B. M.
Professor & Head B.E., M.Tech.,
Department of Civil Engineering
Adichunchanagiri Institute of Technology
CHIKKAMAGALURU-577102


Principal
Principal
Adichunchanagiri Institute of Technology
Chikkamagaluru-577102

ADICHUNCHANAGIRI INSTITUTE OF TECHNOLOGY



Estd: 1980

Accredited by NBA, NAAC,
Affiliated to VTU, Belagavi
Recognised by AICTE, New Delhi, and Govt. of Karnataka
PB No. 91, Adichunchanagiri Extension, KM Road,
CHIKKAMAGALURU 577102, KARNATAKA, INDIA
Phone: Office: 220444, Principal: 220063, Residence: 220343,
Fax: 220063, STD code: 08262



Ref: AIT/CE/ Fitness Certificate: 027 /2026

Date: 27.05.2026

From

The Principal,
A.I.T.,
Chikkamagaluru.

To

The Principal
Sri Sai Angels School ,
Sirgapura
Mallur Post
Chikkamagluru-577133

Sub: Building Inspection Report of Sri Sai Angels School, Located at Assesment No.165, Sirgapura, Mallur Post, Chikkamagluru (D).

Ref: Your letter dated 19.05.2026

With reference to the above, our staff's had inspected the building and conducted NDT test at different locations on structural members to ascertain the quality of the building before issuing the fitness certificate.

Thanking you,

Yours faithfully,

Principal

Adichunchanagiri Institute of Technology
Chikkamagaluru - 577102